



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Jeferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Lead Testing 2016

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: Heuvelton
Received: 09/28/2016 15:00
Reported: 11/07/2016 12:52

Analytical Testing Parameters

Client Sample ID: 4-1
Lab Sample ID: J6J0087-01
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0155, 0.0150, 0.00100, mg/L, G, 10/26/16 0800, 10/31/16 1647

Analytical Testing Parameters

Client Sample ID: 4-2
Lab Sample ID: J6J0087-02
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00130, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1648

Analytical Testing Parameters

Client Sample ID: 6-1
Lab Sample ID: J6J0087-03
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0592, 0.0150, 0.00100, mg/L, G, 10/26/16 0800, 10/31/16 1648



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 6-2
Lab Sample ID: J6J0087-04
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00449, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1650

Analytical Testing Parameters

Client Sample ID: 7-1
Lab Sample ID: J6J0087-05
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00171, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1651

Analytical Testing Parameters

Client Sample ID: 7-2
Lab Sample ID: J6J0087-06
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1653



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 87
Lab Sample ID: J6J0087-07
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1654

Analytical Testing Parameters

Client Sample ID: 3
Lab Sample ID: J6J0087-08
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00187, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1654

Analytical Testing Parameters

Client Sample ID: 2
Lab Sample ID: J6J0087-09
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00764, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1655



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 48
Lab Sample ID: J6J0087-10
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00667, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1656

Analytical Testing Parameters

Client Sample ID: 53
Lab Sample ID: J6J0087-11
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00366, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1656

Analytical Testing Parameters

Client Sample ID: 5-1
Lab Sample ID: J6J0087-12
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0263, 0.0150, 0.00100, mg/L, G, 10/26/16 0800, 10/31/16 1658



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 5-2
Lab Sample ID: J6J0087-13
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00125, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1659

Analytical Testing Parameters

Client Sample ID: 67
Lab Sample ID: J6J0087-14
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00351, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1700

Analytical Testing Parameters

Client Sample ID: 52
Lab Sample ID: J6J0087-15
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00404, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1700



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 66
Lab Sample ID: J6J0087-16
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00317, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1702

Analytical Testing Parameters

Client Sample ID: 68
Lab Sample ID: J6J0087-17
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00514, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1703

Analytical Testing Parameters

Client Sample ID: 64
Lab Sample ID: J6J0087-18
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00334, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1704



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 69
Lab Sample ID: J6J0087-19
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1704

Analytical Testing Parameters

Client Sample ID: 1
Lab Sample ID: J6J0087-20
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0104, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1707

Analytical Testing Parameters

Client Sample ID: 8
Lab Sample ID: J6J0087-21
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0125, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1707



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 49
Lab Sample ID: J6J0087-22
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00444, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1708

Analytical Testing Parameters

Client Sample ID: 60
Lab Sample ID: J6J0087-23
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00237, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1709

Analytical Testing Parameters

Client Sample ID: 59
Lab Sample ID: J6J0087-24
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00327, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1709



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 61
Lab Sample ID: J6J0087-25
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00674, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1710

Analytical Testing Parameters

Client Sample ID: 51
Lab Sample ID: J6J0087-26
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00378, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1712

Analytical Testing Parameters

Client Sample ID: 62
Lab Sample ID: J6J0087-27
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00324, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1713



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 65
Lab Sample ID: J6J0087-28
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0210, 0.0150, 0.00100, mg/L, G, 10/26/16 0800, 10/31/16 1715

Analytical Testing Parameters

Client Sample ID: 63
Lab Sample ID: J6J0087-29
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00248, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1715

Analytical Testing Parameters

Client Sample ID: 46
Lab Sample ID: J6J0087-30
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00321, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1716



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 41
Lab Sample ID: J6J0087-31
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00307, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1717

Analytical Testing Parameters

Client Sample ID: 42
Lab Sample ID: J6J0087-32
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00314, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1717

Analytical Testing Parameters

Client Sample ID: 58
Lab Sample ID: J6J0087-33
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00434, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1718



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 57
Lab Sample ID: J6J0087-34
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00404, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1719

Analytical Testing Parameters

Client Sample ID: 50
Lab Sample ID: J6J0087-35
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00419, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1719

Analytical Testing Parameters

Client Sample ID: 54
Lab Sample ID: J6J0087-36
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00496, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1723



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 56
Lab Sample ID: J6J0087-37
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0119, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1723

Analytical Testing Parameters

Client Sample ID: 40
Lab Sample ID: J6J0087-38
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00388, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1724

Analytical Testing Parameters

Client Sample ID: 35
Lab Sample ID: J6J0087-39
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00259, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1725



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 45
Lab Sample ID: J6J0087-40
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00330, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1725

Analytical Testing Parameters

Client Sample ID: 33
Lab Sample ID: J6J0087-41
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00629, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1726

Analytical Testing Parameters

Client Sample ID: 30
Lab Sample ID: J6J0087-42
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0133, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1727



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 24
Lab Sample ID: J6J0087-43
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00428, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1727

Analytical Testing Parameters

Client Sample ID: 27
Lab Sample ID: J6J0087-44
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0135, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1728

Analytical Testing Parameters

Client Sample ID: 34
Lab Sample ID: J6J0087-45
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00754, 0.0150, 0.00100, mg/L, 10/26/16 0800, 11/02/16 1021



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 29
Lab Sample ID: J6J0087-46
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00824, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1732

Analytical Testing Parameters

Client Sample ID: 32
Lab Sample ID: J6J0087-47
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0132, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1733

Analytical Testing Parameters

Client Sample ID: 22
Lab Sample ID: J6J0087-48
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00396, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1733



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 23
Lab Sample ID: J6J0087-49
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00420, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1734

Analytical Testing Parameters

Client Sample ID: 89
Lab Sample ID: J6J0087-50
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 07:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00235, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1735

Analytical Testing Parameters

Client Sample ID: 39
Lab Sample ID: J6J0087-51
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00307, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1735



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 38
Lab Sample ID: J6J0087-52
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0181, 0.0150, 0.00100, mg/L, G, 10/26/16 0800, 10/31/16 1736

Analytical Testing Parameters

Client Sample ID: 36
Lab Sample ID: J6J0087-53
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00409, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1737

Analytical Testing Parameters

Client Sample ID: 47
Lab Sample ID: J6J0087-54
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0103, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1739



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 44
Lab Sample ID: J6J0087-55
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00370, 0.0150, 0.00100, mg/L, 10/26/16 0800, 11/02/16 1023

Analytical Testing Parameters

Client Sample ID: 43
Lab Sample ID: J6J0087-56
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00361, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1742

Analytical Testing Parameters

Client Sample ID: 28
Lab Sample ID: J6J0087-57
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00221, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1742



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 78
Lab Sample ID: J6J0087-58
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 07:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00116, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1743

Analytical Testing Parameters

Client Sample ID: 31
Lab Sample ID: J6J0087-59
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00489, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1744

Analytical Testing Parameters

Client Sample ID: 37
Lab Sample ID: J6J0087-60
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00446, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1744



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 25
Lab Sample ID: J6J0087-61
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1745

Analytical Testing Parameters

Client Sample ID: 79
Lab Sample ID: J6J0087-62
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 07:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00209, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1747

Analytical Testing Parameters

Client Sample ID: 16
Lab Sample ID: J6J0087-63
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 07:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00137, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1748



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 74
Lab Sample ID: J6J0087-64
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 07:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00719, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1748

Analytical Testing Parameters

Client Sample ID: 75
Lab Sample ID: J6J0087-65
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 07:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00409, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1749

Analytical Testing Parameters

Client Sample ID: 21
Lab Sample ID: J6J0087-66
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 06:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00555, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1751



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 73
Lab Sample ID: J6J0087-67
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 07:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00629, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1752

Analytical Testing Parameters

Client Sample ID: 71
Lab Sample ID: J6J0087-68
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 07:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00264, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1752

Analytical Testing Parameters

Client Sample ID: 72
Lab Sample ID: J6J0087-69
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 07:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00280, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1753



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 9
Lab Sample ID: J6J0087-70
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00590, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1755

Analytical Testing Parameters

Client Sample ID: 12
Lab Sample ID: J6J0087-71
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 07:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00122, 0.0150, 0.00100, mg/L, 10/27/16 0800, 11/01/16 1059

Analytical Testing Parameters

Client Sample ID: 15
Lab Sample ID: J6J0087-72
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 07:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1756



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 13
Lab Sample ID: J6J0087-73
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 07:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00490, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1756

Analytical Testing Parameters

Client Sample ID: 11
Lab Sample ID: J6J0087-74
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 07:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1757

Analytical Testing Parameters

Client Sample ID: 10
Lab Sample ID: J6J0087-75
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00631, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1758



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Analytical Testing Parameters

Client Sample ID: 70
Lab Sample ID: J6J0087-76
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 07:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00155, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1800

Analytical Testing Parameters

Client Sample ID: 88
Lab Sample ID: J6J0087-77
Sample Type: Grab

Collected By: LS-Client
Collection Date: 09/26/16
Collection Time: 07:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00202, 0.0150, 0.00100, mg/L, 10/26/16 0800, 10/31/16 1800

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
MDL: Minimum Detection Limit
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Table with 4 columns: Item, Yes, No, Yes. Rows: Custody Seals Intact and/or No Evidence of Tampering, COC/Labels Agree, Received on Ice (or not required)

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795 New York State Department of Health
Microbac Laboratories, Inc. - Chicagoland NY Lab ID No: 12006 Pennsylvania Department of Environmental Protection
PA DEP ID: 68-04863



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0087

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

A handwritten signature in blue ink that reads "Michael Fifield".

Michael Fifield
Division Manager
11/07/2016 12:52

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at michael.fifield@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

Microbac Laboratories, Inc. Samples must be returned on ice
CHAIN OF CUSTODY

Hewvelton

MNY Workorder #



J6J0087

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oswego BOCES	Invoice #:		Ice:	YES NO	Container Material:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601	PO#:		Cooler:	YES NO	Container Size (in MI):	
Contact:	Ray Filley	Date Req.:		Sample Temp:		Preservative:	
Phone:	315-779-7054			Cooler Seal:	YES NO	Accepted?:	YES NO
Project:	Lead Testing			Pickup:	YES NO	Dropoff:	C W
Quote ID:							
Rush TAT Bus. Day:	< 2-5 5-7 7-10						
Release to DOH:	Yes						
Email Results:	Yes						
Fax Results:	Yes						
	filley@boce5.com						
	fhawk@boce5.com						

Sample Information			Number of Containers for Analysis Requested			Comments/Field Data	
Description/Location	Date	Time	Initial	Matrix Type			
4-1	9/26/16	6:13	YJA				
4-2		6:14					
6-1		6:13					
6-2		6:14					
7-1		6:13					
7-2		6:14					
7							
8							

Print Name and Company	Signature	Date/Time	Comments
Sampled: Linda Shaw	<i>Linda Shaw</i>	9/27 2pm	
Received: D B Scheckle	<i>D B Scheckle</i>	9-28 1500	
Received:			
Received:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this.

Microbac Laboratories, Inc. Samples must be returned on ice
CHAIN OF CUSTODY

Heuvelton

MNY Workorder # _____

Client Information			Billing/Invoice:		
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES				
Address:	20104 NYS Route 3 Watertown, NY 13601				
Contact:	Ray Filley				
Phone:	315-779-7054				
Project:	Lead Testing				
Quote ID:		PO#:			
Rush TAT Bus. Days:	2-5	5-7	7-10	Date Req:	
Relate to DOH:	Yes				
Email Results:	Yes	rfiley@boces.com / rfiley@boces.com			
Fax Results:	Yes				

Sample Information			Number of Containers for Analysis Requested		
Description/Location	Date	Time	Initial	Matrix Type	Comments/Field Data
1 87	9/26/10	6:21	YA	200.8 Lead	
2 3		6:21		P	
3 2		6:23		250	
4 48		6:38		HNO3	
5 53		6:35			
6 5-1		6:13			
7 5-2		6:14			
8					

Receiving Info (Lab Use Only)	
Ice:	YES NO
Cooler:	YES NO
Sample Temp:	
Cooler Seal:	YES NO
Pickup:	YES NO
Dropoff:	C W
Accepted?	YES NO
Container Material	
Container size (in MI)	
Preservative	

Print Name and Company		Signature		Date/Time	
Sampled:	Linda Shaw			9/27 2pm	
Received:	DTZ/kech		Linda Shaw	9-28 1500	
Received:					
Received:					
Received:					
Received:					

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Heuvelton

MNY Workorder # _____

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES						Ice: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	
Address: 20104 NYS Route 3						Cooler: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	
Contact: Watertown, NY 13601						Sample Temp: _____	
Phone: Ray Filley						Cooler Seal: YES <input type="checkbox"/> NO <input type="checkbox"/>	
Project: Lead Testing						Pickup: YES <input type="checkbox"/> NO <input type="checkbox"/>	
Quote ID: _____		PO#: _____				Dropoff: C W	
Rush TAT Bus. Days: < 2-5 5-7 7-10		Date Req: _____				Accepted? YES <input type="checkbox"/> NO <input type="checkbox"/>	
Release to DOH: Yes						Container Material _____	
Email Results: Yes		rfilley@boces.com / rfilley@boces.com				Container size(in Mi) _____	
Fax Results: Yes						Preservative _____	
Sample Information				Comments/Field Data			
Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested	Comments/Field Data	
1 607	9/26/16	6:28	YJA				
2 52		6:35					
3 66		6:28					
4 68		6:27					
5 64		6:29					
6 69		6:27					
7 1		6:23					
8 8		6:24					
Print Name and Company				Signature		Date/Time	
Sampled: Linda Shaw				Linda Shaw		9/27 2pm	
Received: DB Becker						9-28 1:00	
Received:							
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with such.

3821 Buck Drive
 Corland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc. Samples must be returned on ice

CHAIN OF CUSTODY

Heuvelton

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Inneson-Lewis-Hamilton-Herkimer Oneida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES NO
Contact:	Ray Filley					Sample Temp:	YES NO
Phone:	315-779-7054					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:		PO#:				Dropoff:	C W
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req:				Accepted?	YES NO
Release to DOH: Yes						Container Material	
Email Results: Yes	rfilley@boces.com					Container Size(in MI)	
Fax Results: Yes	ffhawk@boces.com					Preservative	
Sample Information		Number of Containers for Analysis Requested		Comments/Field Data			
Description/Location	Date	Time	Initial	Matrix Type			
1 49	9/26/16	6:37	YJA				
2 60		6:32					
3 59		6:32					
4 61		6:31					
5 51		6:36					
6 62		6:30					
7 65		6:30					
8 63		6:30					
Print Name and Company		Signature		Date/Time			
Sampled: Linda Snow		Linda Snow		9/27 2pm			
Received: D Brechele				9/28 1500			
Received:							
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00895

Microbac Laboratories, Inc. Samples must be returned on ice

CHAIN OF CUSTODY

Hewvelton

MNY Workorder #

Client Information			Billing/Invoice:			Analysis Requested			Receiving Info (Lab Use Only)					
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES		PO#:			Ice:	YES	NO	Container Material		Accepted?	YES	NO	
Address:	20104 NYS Route 3 Watertown, NY 13601		Date Req:			Cooler:	YES	NO	Container size(in MI)		Preservative			
Contact:	Ray Filley					Sample Temp:	YES	NO	Comments/Field Data					
Phone:	315-779-7054					Cooler seal:	YES	NO						
Project:	Lead Testing					Pickup:	YES	NO						
Quote ID:						Dropoff:	C	W						
Rush TAT Bus. Days:	< 2-5 5-7 7-10					Accepted?	YES	NO						
Release to DOH: Yes						Container Material								
Email Results: Yes	filley@boces.com					Container size(in MI)								
Fax Results: Yes	filley@boces.com					Preservative								
	filley@boces.com					Number of Containers for Analysis Requested								
	filley@boces.com													
Sample Information			Matrix			Type			Signature					
Description/Location	Date	Time	Initial	Initial	Initial	Date/Time	Date/Time	Date/Time	Date/Time	Date/Time	Date/Time	Date/Time	Date/Time	
1 410	9/26/16	6:39	YA											
2 41		6:41												
3 42		6:41												
4 58		6:32												
5 57		6:24												
6 50		6:36												
7 54		6:35												
8 56		6:34												
Sampled: Linda Spaw						Signature			Date/Time			Comments		
Received: DTS Fechele						Linda Spaw			9/27 2pm					
Received:									9-28-1500					
Received:														
Received:														
Received:														

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with it.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3416
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Heuvelton

MNY Workorder #

Client Information		Billing/Invoices		Analysis Requested		Receiving Info (Lab Use Only)	
Name: Jefferson-Lewis-Hamilton-Herkimer Oneida BOCES		20104 NYS Route 3				Ice: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	
Address: Watertown, NY 13601		Ray Filley				Cooler: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	
Contact: 315-779-7054		Lead Testing				Sample Temp: YES <input type="checkbox"/> NO <input type="checkbox"/>	
Project: PO#: 200.8 Lead		Date Req: P				Cooler Seal: YES <input type="checkbox"/> NO <input type="checkbox"/>	
Rush TAT Bus. Days: 2-5 5-7 7-10		Email Results: Yes				Pickup: YES <input type="checkbox"/> NO <input type="checkbox"/>	
Release to DOH: Yes		Fax Results: Yes				Dropoff: C W	
Email Results: Yes		Matrix Type				Accepted? YES <input type="checkbox"/> NO <input type="checkbox"/>	
Fax Results: Yes		Sample Information				Container Material	
Description/Location		Date	Time	Initial	Matrix Type	Container Size (in Mil)	
1 LTD		9/26/16	6:42	YA		Preservative	
2 35			6:45			Comments/Field Data	
3 45			6:39				
4 33			6:46				
5 30			6:48				
6 24			6:53				
7 27			6:50				
8 34			6:36				
Sampled: Linda Snow		Signature		Date/Time		Comments	
Received: D B Steefe		Linda Snow		9/27 2pm			
Received:				9-28-1500			
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with the terms and conditions.

Microbac Laboratories, Inc. Samples must be returned on ice

CHAIN OF CUSTODY

Hewvelton

MNY Workorder #

Client Information			Billing/Invoice:			Analysis Requested			Receiving Info (Lab Use Only)				
Name:	Jefferson-Lewis-Hamilton-Hecklinger, Onelda BOCBS					Ice:	YES	NO				YES	NO
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES	NO				YES	NO
Contact:	Ray Filley					Sample Temp:						YES	NO
Phone:	315-779-7054					Cooler seal:	YES	NO				YES	NO
Project:	Lead Testing					Pickup:	YES	NO				YES	NO
Quote ID:			PO#:			Dropoff:	C	W					
Rush TAT Bus. Days:	2-5	5-7	7-10	Date Req:		Accepted?	YES	NO				YES	NO
Relocate to DOH: Yes						Container Material							
Email Results: Yes	rfiley@bocbs.com					Container size (in Mi)							
Fax Results: Yes	rfiley@bocbs.com					Preservative							
						Comments/Field Data							
Sample Information			Number of Containers for Analysis Requested			Comments/Field Data							
Description/Location	Date	Time	Initial	Matrix Type									
1 29	9/26/16	6:41	YA										
2 32		6:47											
3 22		6:55											
4 23		6:53											
5 89		7:12											
6 39		6:42											
7 38		6:45											
8 36		6:45											
Print Name and Company			Signature			Date/Time							
Sampled: Linda Snow			Linda Snow			9/27 2pm							
Received: D Breche			Signature			9-28/1500							
Received:													
Received:													
Received:													
Received:													

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with MNY.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY000936

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder #

Hewvelton

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES			Ice:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	Container Material	YES <input type="checkbox"/> NO <input type="checkbox"/>
Address:	20104 NYS Route 3 Watertown, NY 13601			Cooler:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	Container Size (in MI)	YES <input type="checkbox"/> NO <input type="checkbox"/>
Contact:	Ray Filley			Sample Temp:		Preervative	
Phone:	315-779-7054			Cooler Seal:	YES <input type="checkbox"/> NO <input type="checkbox"/>	Accepted?	YES <input type="checkbox"/> NO <input type="checkbox"/>
Project:	Lead Testing			Pickup:	YES <input type="checkbox"/> NO <input type="checkbox"/>	Container Material	
Quote ID:		PO#:		Dropoff:	C <input type="checkbox"/> W <input type="checkbox"/>	Preervative	
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req.:				Comments/Field Data	
Relocate to DOH:	Yes						
Email Results:	Yes	Email:	filley@boces.com / fhack@boes.com				
Fax Results:	Yes						
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Matrix Type	1	2	3
1	9/26/10	7:10	YA				
2		7:12					
3		7:12					
4		7:12					
5		7:09					
6		7:10					
7		7:06					
8		7:04					
Print Name and Company				Signature	Date/Time		
Sampled: Linda Snow				Linda Snow	9/27 2pm		
Received: D Breche					9-28 1500		
Received:							
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this arrangement.